



NORTH DAVIS SEWER DISTRICT

## Addendum

---

**To:** All suppliers bidding MSGR Battery Replacement      **Date:** 2/25/2025  
**From:** Myron Bachman Plant Superintendent  
**Subject:** Clarification on Battery performance test requirements

---

The question was asked for clarification on the requirements of the battery load test to show they meet expectations. Was asked to define the length of time and amount of load during load test.

**Answer: The load test needs to be for 1.5 hours at 32.9 amps.**