



NORTH DAVIS SEWER DISTRICT

ND-17 Standard Service Connection - 1 of 2

NOTES:

1. CONTRACTOR MUST NOTIFY THE DISTRICT 48 HOURS BEFORE WORK BEGINS.
2. CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTION OF EXISTING SEWER AND OTHER UTILITIES, PROPER BACKFILLING, COMPACTING, AND SURFACE RESTORATION.
3. CONTRACTOR MUST ACCURRATELY SIZE AND PROCURE CONNECTION FITTINGS BASED ON THE EXISTING DISTRICT SEWER (MATERIAL AND DIAMETER) AND THE LATERAL SEWER (MATERIAL AND DIAMETER) TO BE CONNECTED.
4. CORE DRILLING OF CONCRETE PIPE SHALL USE THE WET DIAMOND BIT PROCESS. DO NOT ATTACH GUIDES TO THE EXISTING PIPE TO PERFORM CORE DRILLING. CORE DRILL DIAMETER SHALL BE PER THE CONNECTION MANUFACTURER'S REQUIREMENTS. CONTRACTOR SHALL BE RESPONSIBLE TO REPAIR OR REPLACE DAMAGED PIPE. CORES SHALL BE RETAINED AND NOT ALLOWED TO FALL INTO THE SEWER.
5. CONTRACTOR SHALL MEASURE THE DISTANCE FROM THE NEAREST MANHOLE TO THE CENTER OF THE CONNECTION AND FURNISH MEASUREMENTS TO THE DISTRICT.
6. CONTRACTOR SHALL MANUALLY BACKFILL AND COMPACT AROUND THE CONNECTION UNTIL A MINIMUM OF 12" OF COVER IS PLACED OVER THE PIPE AND CONNECTION.
7. SEE ND-06 FOR ACCEPTANCE TESTING, FINAL COMPLETION, AND WARRANTY REQUIREMENTS.

